


LUMINAIRE PHOTOMETRIC TEST REPORT


NAME: Lanzarote 2850k	TYPE:	WEIGHT:1
SPEC.:	DIM.: 3x10x500mm	SERIAL No.:
MFR.: Luz Negra s.l.	SUR.:22	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA				Eff: 91.83 lm/W
MODEL	33.016	I _{max} (cd)	323.3	S/MH(C0/180)	1.25	
NOMINAL POWER(W)	18w/m	LOR(%)	100.0	S/MH(C90/270)	1.29	
RATED VOLTAGE(V)	24,4	TOTAL FLUX(lm)	955.12	η UP,DN(C0-180)	0.1,49.2	
NOMINAL FLUX(lm)	955.118	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.1,50.6	
LAMPS INSIDE	1	η up(%)	0.3	CIBSE SHR NOM	1.25	
TEST VOLTAGE(V)	24,4	η down(%)	99.7	CIBSE SHR MAX	1.35	

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25DEG
Operators:Marçal Huguet
Test Date:March 2021

γ Range: 0 - 110DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.400
Humidity:37%
Test Distance:8.200m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:


γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum,lamp
10	319.8	318.6	316.8	315.5	315.9	317.2	319.0	320.2	0- 10	30.59	30.59	3.2,3.2
20	306.4	304.0	300.4	298.2	298.7	301.4	304.7	307.1	10- 20	87.94	118.5	12.4,12.4
30	282.8	279.1	273.7	271.0	272.2	275.9	280.4	283.8	20- 30	134.2	252.7	26.5,26.5
40	249.5	244.3	237.7	234.7	237.0	241.5	246.8	250.9	30- 40	163.4	416.1	43.6,43.6
50	206.9	200.7	193.4	190.7	193.6	198.9	204.5	208.8	40- 50	171.4	587.4	61.5,61.5
60	156.3	149.6	142.9	139.9	143.3	149.3	155.0	159.0	50- 60	156.6	744.1	77.9,77.9
70	99.40	93.44	87.72	85.34	87.95	94.48	99.93	102.8	60- 70	120.7	864.7	90.5,90.5
80	40.98	36.44	34.12	32.35	33.17	38.94	42.90	44.54	70- 80	69.02	933.8	97.8,97.8
90	2.379	2.641	0.6390	3.944	1.415	5.011	0.9376	4.476	80- 90	18.87	952.6	99.7,99.7
100	0.7614	0.7105	0.7326	0.7631	0.9912	0.8294	0.7553	0.7679	90-100	1.420	954.0	99.9,99.9
110	0.9700	1.022	1.265	1.073	1.218	1.171	1.143	1.108	100-110	1.015	955.1	100,100
120	0	0	0	0	0	0	0	0	110-120	0.0587	955.1	100,100
130	0	0	0	0	0	0	0	0	120-130	0	955.1	100,100
140	0	0	0	0	0	0	0	0	130-140	0	955.1	100,100
150	0	0	0	0	0	0	0	0	140-150	0	955.1	100,100
160	0	0	0	0	0	0	0	0	150-160	0	955.1	100,100
170	0	0	0	0	0	0	0	0	160-170	0	955.1	100,100
180	0	0	0	0	0	0	0	0	170-180	0	955.1	100,100
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25DEG
 Operators:Marçal Huguet
 Test Date:March 2021

γ Range: 0 - 110DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.400
 Humidity:37%
 Test Distance:8.200m [K=1.0000]
 Remarks:

LUMINANCE LIMITATION CURVES

NAME: Lanzarote 2850k	TYPE:	WEIGHT:1
SPEC.:	DIM.: 3x10x500mm	SERIAL No.:
MFR.: Luz Negra s.l.	SUR.:22	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25DEG
Operators: Marçal Huguet
Test Date: March 2021

γ Range: 0 - 110DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-2000B_V1 SYSTEM V2.0.400
Humidity: 37%
Test Distance: 8.200m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

NAME: Lanzarote 2850k	TYPE:	WEIGHT:1
SPEC.:	DIM.: 3x10x500mm	SERIAL No.:
MFR.: Luz Negra s.l.	SUR.:22	Shielding Angle:

ρ_{cc}	80%			70%			50%			30%			10%			0
ρ_w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρ_{fc}	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio															



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25DEG
Operators: Marçal Huguet
Test Date: March 2021

γ Range: 0 - 110DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-2000B_V1 SYSTEM V2.0.400
Humidity: 37%
Test Distance: 8.200m [K=1.0000]
Remarks:

WEC AND CCEC

NAME: Lanzarote 2850k	TYPE:	WEIGHT:1
SPEC.:	DIM.: 3x10x500mm	SERIAL No.:
MFR.: Luz Negra s.l.	SUR.:22	Shielding Angle:

ρ_{CC}	80%			70%			50%			30%			10%			0
ρ_W	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρ_{fC}	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio Wall Exitance Coefficients(WEC)															
0.0																
1.0	.313	.178	.056	.306	.175	.055	.293	.168	.054	.280	.162	.052	.269	.156	.050	
2.0	.295	.161	.050	.288	.159	.049	.276	.154	.048	.266	.149	.047	.255	.144	.046	
3.0	.272	.145	.043	.267	.143	.043	.256	.139	.042	.247	.135	.041	.238	.132	.041	
4.0	.251	.131	.038	.246	.129	.038	.237	.126	.038	.228	.123	.037	.220	.120	.036	
5.0	.232	.118	.034	.228	.117	.034	.219	.114	.034	.212	.112	.033	.204	.109	.033	
6.0	.215	.108	.031	.211	.107	.031	.204	.104	.030	.197	.102	.030	.190	.100	.030	
7.0	.200	.099	.028	.197	.098	.028	.190	.096	.028	.184	.094	.027	.178	.092	.027	
8.0	.187	.091	.026	.184	.090	.026	.178	.089	.025	.172	.087	.025	.167	.086	.025	
9.0	.175	.085	.024	.172	.084	.024	.167	.082	.023	.162	.081	.023	.157	.080	.023	
10.0	.164	.079	.022	.162	.078	.022	.157	.077	.022	.153	.076	.022	.148	.075	.021	

ρ_{CC}	80%			70%			50%			30%			10%			0
ρ_W	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρ_{fC}	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio Ceiling Cavity Exitance Coefficients(CCEC)															
0.0	.192	.192	.192	.164	.164	.164	.112	.112	.112	.064	.064	.064	.021	.021	.021	
1.0	.183	.158	.136	.156	.136	.117	.107	.093	.081	.061	.054	.047	.020	.017	.015	
2.0	.175	.134	.100	.150	.115	.086	.103	.080	.060	.059	.046	.035	.019	.015	.011	
3.0	.167	.116	.076	.143	.100	.066	.098	.070	.046	.057	.041	.027	.018	.013	.009	
4.0	.159	.103	.060	.137	.089	.052	.094	.062	.037	.054	.036	.022	.018	.012	.007	
5.0	.152	.093	.049	.131	.080	.043	.090	.056	.030	.052	.033	.018	.017	.011	.006	
6.0	.145	.084	.041	.124	.073	.036	.086	.051	.025	.050	.030	.015	.016	.010	.005	
7.0	.138	.077	.035	.119	.067	.031	.082	.047	.022	.048	.028	.013	.015	.009	.004	
8.0	.131	.072	.031	.113	.062	.027	.078	.044	.019	.046	.026	.011	.015	.008	.004	
9.0	.125	.067	.027	.108	.058	.024	.075	.041	.017	.044	.024	.010	.014	.008	.003	
10.0	.120	.062	.024	.103	.054	.021	.072	.038	.015	.042	.023	.009	.014	.007	.003	

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25DEG
 Operators:Marçal Huguet
 Test Date:March 2021

γ Range: 0 - 110DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.400
 Humidity:37%
 Test Distance:8.200m [K=1.0000]
 Remarks:

UGR(Unified Glare Rating) Table

NAME: Lanzarote 2850k					TYPE:		WEIGHT:1				
SPEC.:					DIM.: 3x10x500mm		SERIAL No.:				
MFR.: Luz Negra s.l.					SUR.:22		Shielding Angle:				
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3	
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3	
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
Room dimensions		Viewed crosswise					Viewed endwise				
x = 2H y = 2H	2H	14.7	16.3	15.0	16.5	16.7	14.4	15.9	14.7	16.1	16.4
	3H	16.3	17.8	16.6	18.0	18.2	15.9	17.3	16.2	17.5	17.8
	4H	17.0	18.3	17.3	18.6	18.8	16.4	17.8	16.8	18.1	18.3
	6H	17.4	18.7	17.7	19.0	19.2	16.8	18.1	17.2	18.4	18.6
	8H	17.5	18.8	17.9	19.1	19.4	16.9	18.1	17.3	18.4	18.7
	12H	17.6	18.8	18.0	19.1	19.4	17.0	18.1	17.3	18.4	18.8
4H	2H	15.3	16.7	15.6	16.9	17.2	15.1	16.4	15.4	16.7	16.9
	3H	17.1	18.3	17.5	18.6	18.9	16.7	17.9	17.1	18.2	18.5
	4H	17.9	18.9	18.2	19.3	19.6	17.4	18.5	17.8	18.8	19.2
	6H	18.4	19.4	18.8	19.7	20.1	17.9	18.8	18.3	19.2	19.6
	8H	18.6	19.5	19.0	19.9	20.2	18.0	18.9	18.4	19.3	19.7
	12H	18.7	19.5	19.1	19.9	20.3	18.1	18.9	18.6	19.3	19.7
8H	4H	18.1	19.0	18.5	19.3	19.7	17.7	18.6	18.1	18.9	19.3
	6H	18.8	19.5	19.2	19.9	20.4	18.3	19.0	18.7	19.5	19.9
	8H	19.0	19.7	19.5	20.1	20.6	18.5	19.2	19.0	19.6	20.1
	12H	19.2	19.7	19.7	20.2	20.7	18.7	19.2	19.2	19.7	20.2
12H	4H	18.1	18.9	18.5	19.3	19.7	17.7	18.5	18.1	18.9	19.3
	6H	18.8	19.5	19.3	19.9	20.4	18.3	19.0	18.8	19.4	19.9
	8H	19.1	19.6	19.6	20.1	20.6	18.6	19.2	19.1	19.6	20.1
Variations with the observer position at spacings:											
S = 1.0H	+ 0.1 / - 0.2					+ 0.2 / - 0.2					
1.5H	+ 0.2 / - 0.3					+ 0.2 / - 0.3					
2.0H	+ 0.2 / - 0.3					+ 0.2 / - 0.3					

CIE Pub.117, 955.1 lm Total Lamp Luminous Flux Correct ($8\log(F/F_0) = -0.2$)

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25DEG
Operators:Marçal Huguet
Test Date:March 2021

γ Range: 0 - 110DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.400
Humidity:37%
Test Distance:8.200m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

NAME: Lanzarote 2850k	TYPE:	WEIGHT:1
SPEC.:	DIM.: 3x10x500mm	SERIAL No.:
MFR.: Luz Negra s.l.	SUR.:22	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) $k(RI) \times RCR = 5$									
k = 0.60	57	45	38	56	45	38	55	44	38	31
0.80	67	55	48	66	55	48	64	54	47	40
1.00	75	64	57	74	64	56	72	65	56	49
1.25	83	72	65	81	71	64	78	70	63	56
1.50	88	78	70	86	77	70	83	75	69	61
2.00	95	86	79	93	85	78	89	82	77	69
2.50	98	91	84	96	89	84	93	87	82	73
3.00	102	95	89	100	93	88	96	90	86	77
4.00	106	100	95	104	98	94	99	95	91	82
5.00	108	104	99	106	102	98	101	98	95	85
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25DEG
 Operators:Marçal Huguet
 Test Date:March 2021

γ Range: 0 - 110DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.400
 Humidity:37%
 Test Distance:8.200m [K=1.0000]
 Remarks:

ISOCANDELA DIAGRAM

NAME: Lanzarote 2850k	TYPE:	WEIGHT:1
SPEC.:	DIM.: 3x10x500mm	SERIAL No.:
MFR.: Luz Negra s.l.	SUR.:22	Shielding Angle:




C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25DEG
 Operators: Marçal Huguet
 Test Date: March 2021

γ Range: 0 - 110DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-2000B_V1 SYSTEM V2.0.400
 Humidity: 37%
 Test Distance: 8.200m [K=1.0000]
 Remarks:

AAI Figure

NAME: Lanzarote 2850k	TYPE:	WEIGHT:1
SPEC.:	DIM.: 3x10x500mm	SERIAL No.:
MFR.: Luz Negra s.l.	SUR.:22	Shielding Angle:




Note: The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25DEG
Operators: Marçal Huguet
Test Date: March 2021

γ Range: 0 - 110DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-2000B_V1 SYSTEM V2.0.400
Humidity: 37%
Test Distance: 8.200m [K=1.0000]
Remarks:

ISOLUX DIAGRAM

NAME: Lanzarote 2850k	TYPE:	WEIGHT:1
SPEC.:	DIM.: 3x10x500mm	SERIAL No.:
MFR.: Luz Negra s.l.	SUR.:22	Shielding Angle:



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25DEG
Operators: Marçal Huguet
Test Date: March 2021

γ Range: 0 - 110DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-2000B_V1 SYSTEM V2.0.400
Humidity: 37%
Test Distance: 8.200m [K=1.0000]
Remarks:

LED Avg.L Report

NAME: Lanzarote 2850k	TYPE:	WEIGHT:1
SPEC.:	DIM.: 3x10x500mm	SERIAL No.:
MFR.: Luz Negra s.l.	SUR.:22	Shielding Angle:


AvgL	cd/m2
L_0~180(65)av	1447
L_0~180(75)av	1250
L_0~180(85)av	811
L_90~270(65)av	1443
L_90~270(75)av	1263
L_90~270(85)av	1002
L_45(65)av	1446
L_45(75)av	1265
L_45(85)av	855

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25DEG
Operators:Marçal Huguet
Test Date:March 2021

γ Range: 0 - 110DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.400
Humidity:37%
Test Distance:8.200m [K=1.0000]
Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25DEG
 Operators: Marçal Huguet
 Test Date: March 2021

γ Range: 0 - 110DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-2000B_V1 SYSTEM V2.0.400
 Humidity: 37%
 Test Distance: 8.200m [K=1.0000]
 Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: Lanzarote 2850k	TYPE:	WEIGHT:1
SPEC.:	DIM.: 3x10x500mm	SERIAL No.:
MFR.: Luz Negra s.l.	SUR.:22	Shielding Angle:

Table--1

UNIT: cd

C(°) \ γ (°)	0	22.5	45	67.5	90	112.5	135	157.5	180	202.5	225	247.5	270	292.5	315	337.5			
0	323	323	323	323	323	323	323	323	323	323	323	323	323	323	323	323			
5	323	323	322	322	321	321	321	321	321	321	321	322	322	323	323	323			
10	320	319	319	318	317	316	316	315	316	316	317	318	319	320	320	320			
15	314	314	313	311	310	309	308	308	309	309	311	312	313	314	315	315			
20	306	306	304	302	300	299	298	298	299	299	301	303	305	306	307	307			
25	296	295	293	291	288	287	286	285	287	287	290	291	294	295	297	296			
30	283	282	279	277	274	272	271	271	272	273	276	278	280	282	284	283			
35	267	266	263	260	257	255	254	254	256	257	260	262	265	266	268	268			
40	249	248	244	242	238	236	235	235	237	238	242	243	247	248	251	250			
45	229	228	224	221	217	215	214	214	216	217	221	223	227	228	231	230			
50	207	205	201	198	193	192	191	192	194	195	199	201	205	206	209	208			
55	183	181	176	173	169	167	166	167	169	171	175	177	181	182	185	184			
60	156	154	150	147	143	142	140	140	143	145	149	151	155	156	159	158			
65	128	126	122	119	116	115	113	113	116	118	122	125	128	129	131	131			
70	99.4	97.1	93.4	91.0	87.7	86.7	85.3	85.4	88.0	90.3	94.5	96.9	99.9	101	103	101			
75	69.7	67.7	64.4	62.6	59.8	59.1	57.8	57.8	59.7	62.3	66.3	68.7	71.0	72.2	73.5	72.0			
80	41.0	39.2	36.4	36.0	34.1	33.8	32.3	31.8	33.2	35.7	38.9	41.2	42.9	43.4	44.5	43.3			
85	16.5	14.3	12.0	14.6	14.3	14.5	12.8	11.6	11.8	14.0	17.1	19.4	20.6	20.0	17.8	17.8			
90	2.38	2.48	2.64	2.73	0.64	4.19	3.94	2.55	1.42	2.82	5.01	6.27	0.94	4.31	4.48	3.70			
95	0.81	1.04	0.99	0.60	0.56	0.68	1.40	1.45	1.13	1.46	1.51	0.78	0.59	0.68	1.15	1.16			
100	0.76	0.75	0.71	0.70	0.73	0.72	0.76	0.92	0.99	0.91	0.83	0.78	0.76	0.75	0.77	0.83			
105	0.80	0.83	0.85	0.88	1.35	0.91	0.91	0.98	1.02	1.00	0.98	1.21	0.94	0.92	0.93	0.93			
110	0.97	0.99	1.02	1.26	1.27	1.09	1.07	1.13	1.22	1.18	1.17	1.44	1.14	1.10	1.11	1.10			
115	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
120	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
125	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
130	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
135	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
140	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
145	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
150	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
155	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
160	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
165	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
170	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
175	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
180	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25DEG
Operators: Marçal Huguet
Test Date: March 2021

γ Range: 0 - 110DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-2000B_V1 SYSTEM V2.0.400
Humidity: 37%
Test Distance: 8.200m [K=1.0000]
Remarks: